

EXCHANGE CHECKLIST

To assure your safety and proper operation, all propane exchange cylinders must meet local, state and federal regulations. In accordance with NFPA 58 standards and NPGA Safety Bulletin No. 118,

....PLEASE DO NOT ASK FOR AN EXCEPTION



PROTECTIVE COLLAR

20# cylinders without collar are not approved for exchange



EXCESSIVE RUST

20# cylinders with excessive rust are not approved for exchange



FOOT RING

20# cylinders without foot ring are not approved for exchange



D.O.T. LABELS

20# cylinders without PROPER 1075 gas label are not approved for exchange



GAS VALVE

20# cylinders without gas valve are not approved for exchange



POL PLUG/DUST CAP

20# cylinders without POL plug or DUST cap are not approved for exchange



EXCESSIVE DENTS

20# cylinders with excessive dents are not approved for exchange



OK

Cylinders with a 4" Protective Collar, Foot Ring, Upright Gas Valve, No Severe Rust or Dents, Proper Required 1075 D.O.T. Label and POL Plug or Dust cap for Valve Opening are Approved for Exchange

Eligible DOT cylinders will require an OPD valve at DOT re-certification beginning October 1998

FEDERAL AND STATE REGULATIONS REQUIRE HAULING PROPANE CYLINDERS SECURED IN A VERTICAL POSITION

NOTICE:

Over filling of propane container is in violation of State and Federal Laws State Law prohibits the use of propane cylinders larger than one pound in living areas for comfort heating. We refuse to exchange cylinders that are intended for this purpose.

IMPORTANT CONSUMER NOTICE:

All propane cylinders for exchange must have a visual external inspection by a certified propane dealer 12 years after date of manufacture and every 5 years thereafter.

REFERENCE: D.O.T. as published in Code of Federal Regulations Title 49, parts 100-180 specifications; D.O.T. ICC 4B, 4bA, 4BW, 4E AND 26-300 Cylinders When Used In Propane Gas Service.